

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	8:48 AM	GT	PEE-D-01	Hall by Classroom 112	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Cooler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	8:50 AM	GT	PEE-D-02	Hall by Classroom 112	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Cooler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	8:54 AM	GT	PEE-D-03	Hall by Classroom 112	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Cooler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	8:55 AM	GT	PEE-D-04	Hall by Classroom 112	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Cooler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	8:57 AM	GT	PEE-BF-05	Hall by Teach. Lounge	O - Other	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Bottle Filler on Water Cooler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:00 AM	GT	PEE-D-06	Hall by Teach. Lounge	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:02 AM	GT	PEE-BF-07	Hall by Teach. Lounge	O - Other	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Bottle Filler on Water Cooler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:03 AM	GT	PEE-S-08	Teachers' Lounge	S - Sink	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.26	2.00	
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:04 AM	GT	PEE-S-09	Teachers' Lounge	S - Sink	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:06 AM	GT	PEE-BF-10	Hall by NE Restrooms	O - Other	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.79	2.00	Bottle Filler on Water Cooler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:07 AM	GT	PEE-D-11	Hall by NE Restrooms	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	3.54	2.00	
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:08 AM	GT	PEE-BF-12	Hall by NE Restrooms	O - Other	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.88	2.00	Bottle Filler on Water Cooler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:11 AM	GT	PEE-D-13	Hall by NE Restrooms	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.80	2.00	
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:12 AM	GT	PEE-D-14	Hall by NE Restrooms	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.91	2.00	
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:14 AM	GT	PEE-D-15	Hall by Room 144	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:15 AM	GT	PEE-D-16	Hall by Room 144	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:16 AM	GT	PEE-D-17	Hall by Room 144	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:17 AM	GT	PEE-D-18	Hall by Room 144	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:19 AM	GT	PEE-D-19	Hall by Rooms 13 & 14	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:20 AM	GT	PEE-D-20	Hall by Rooms 13 & 14	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.61	2.00	Right Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:21 AM	GT	PEE-D-21	Hall by Rooms 13 & 14	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.50	2.00	Left Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:22 AM	GT	PEE-D-22	Hall by Rooms 13 & 14	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:23 AM	GT	PEE-D-23	Hall Outside Gym	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Far Right Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:24 AM	GT	PEE-D-24	Hall Outside Gym	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Far Right Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:25 AM	GT	PEE-D-25	Hall Outside Gym	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Center-Right Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:26 AM	GT	PEE-D-26	Hall Outside Gym	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Center-Right Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:27 AM	GT	PEE-BF-27	Hall Outside Gym	O - Other	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Center-Left Bottle Filler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:28 AM	GT	PEE-D-28	Hall Outside Gym	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Center-Left Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:29 AM	GT	PEE-BF-29	Hall Outside Gym	O - Other	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.03	2.00	Center-Left Bottle Filler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:30 AM	GT	PEE-D-30	Hall Outside Gym	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Far Left Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:31 AM	GT	PEE-D-31	Hall Outside Gym	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Far Left Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:34 AM	GT	PEE-BF-32	Hall by Classroom 40	O - Other	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Bottle Filler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:35 AM	GT	PEE-D-33	Hall by Classroom 40	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.96	2.00	Right Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:36 AM	GT	PEE-BF-34	Hall by Classroom 40	O - Other	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.26	2.00	Right Bottle Filler
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:37 AM	GT	PEE-D-35	Hall by Classroom 40	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:38 AM	GT	PEE-D-36	Hall by Classroom 40	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:41 AM	GT	PEE-S-37	Art Room	S - Sink	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:42 AM	GT	PEE-S-38	Art Room	S - Sink	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:43 AM	GT	PEE-S-39	Art Room	S - Sink	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:44 AM	GT	PEE-S-40	Art Room	S - Sink	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:47 AM	GT	PEE-D-41	Hall by Commons Area	F - Water Cooler	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:48 AM	GT	PEE-D-42	Hall by Commons Area	F - Water Cooler	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:50 AM	GT	PEE-S-43	ARA Kitchen	KS - Kitchen Sink	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	3.60	2.00	Left Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:51 AM	GT	PEE-S-44	ARA Kitchen	KS - Kitchen Sink	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.40	2.00	Left Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:52 AM	GT	PEE-S-45	ARA Kitchen	KS - Kitchen Sink	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:53 AM	GT	PEE-S-46	ARA Kitchen	KS - Kitchen Sink	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:55 AM	GT	PEE-S-47	Commons Area Kitchen	KS - Kitchen Sink	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:56 AM	GT	PEE-S-48	Commons Area Kitchen	KS - Kitchen Sink	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	9:59 AM	GT	PEE-S-49	Music Room	S - Sink	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	77.30	2.00	Left Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	10:01 AM	GT	PEE-S-50	Music Room	S - Sink	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	13.60	2.00	Left Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	10:03 AM	GT	PEE-S-51	Music Room	S - Sink	6/5/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	37.10	2.00	Right Sink
14-016-1180-04-2002	0001	Palos East Elem.	6/6/17	10:04 AM	GT	PEE-S-52	Music Room	S - Sink	6/5/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	21.90	2.00	Right Sink